

Building Department

Research & Building Systems Section

New Hospitals and Clinics Checklist



New Hospitals & Clinics

Entrance	Path	Level Changes Stairs, Ramp, Elevators	Sanitary Provisions	Changing Room	Furniture	Parking & drop off point	Accessible Rooms
----------	------	---	------------------------	------------------	-----------	-----------------------------	------------------

All	UA*	UA	UA	UA	UA	UA	UA
------------	-----	----	----	----	----	----	----

UA
Universally Accessible

UA*
When the building is built in a floodable zone the entrances of the building can have a change in level from the exterior floor level. In this exceptional case the entrances solutions may be permitted.

CODE	CRITERIA	EVALUATION			COMMENTS	AUDIT PHASE
E	Entrance	YES	N/A	NON		
E1	Gradients of entrances ≤ 5%					PERMIT
E2	When several paths, both accessible and inaccessible marked					ACCOMPLISH
E3	If accessible door not the main door, it is marked with directional sign					ACCOMPLISH
E4	Identification number and exact address for each entrance					OPERATION
E5	In public use buildings, reception desk near the entrance					ACCOMPLISH
E6	Dimensions doors ≥ 900mm width x 2100mm height					PERMIT
E7	Automatic door					ACCOMPLISH
E8	3 seconds or more to move from closed to fully open position - Remain fully open for a minimum 5 seconds - Force not more than 66N					ACCOMPLISH
E9	Doormats levelled with ± 2mm					ACCOMPLISH
E10	Access controls barriers with at least one barrier with width ≥ 900mm if provided					OPERATION
EGT	Guiding tactile pavements					

SPab2	One accessible ablation unit linked to an accessible path. The closest from the entrance							PERMIT
SPab3	Two horizontal bars mounted between 700 – 800 mm with the same length of wash basin							ACCOMPLISH
SPab4	All Accessories at a height between 700 - 1200 mm							ACCOMPLISH
SPab5	Provides bidet shower system, soap and paper							ACCOMPLISH
SPab6	Approaching free space of 1200 mm							ACCOMPLISH
SPab7	The approaching free space with contrast ≥ 30 points LRV							ACCOMPLISH

CHR	Changing rooms							Audit Phase
	Accessible dressing or changing rooms							
CHR1	Corridors width ≥ 1000mm and direction changes with maneuvering turning space of 1500mm						NON	PERMIT
CHR2	Approaching space for lockers, benches and furniture 1420 x 865mm							PERMIT
CHR3	1 of 10 showers is accessible, if provided							PERMIT
CHR4	1 of 10 toilet is accessible, if provided							PERMIT

FU	Furniture							Audit Phase
	FU1	Without sharp edges, protruding objects, burning surfaces. With contrasting colour. Made with non-toxic material, and noted if causing allergy						
FU	Tables							
Fut1	Height of the top ≤ 800 mm							OPERATION

FUv6	Control buttons with high embossed text and Braille								OPERATION
FUv7	Card slot height between 800 - 1200 mm								OPERATION
FUv8	Visual and acoustic indication system and alarm system provided								OPERATION
FUv9	Audio information provided								OPERATION
FUv10	CCTV Intercom provided								OPERATION
FUv11	Slots are wide and have a funnel effect								OPERATION
FUv	Bollards, planters, telephone booths and other furniture elements, if provided								
FUv1	Outside the accessible path or do not reduce accessible path \leq 1200mm								OPERATION

PA	Parking and drop off point	YES	N/A	NON	Comments	Audit Phase
PA1	Pick up & drop off area provided					PERMIT
Accessible parking places, access to parking lots						
PA2	Number of accessible parking lots, if parking facilities provided: 1.3 % of the total number of parking spots. A partial parking to be considered as a full parking at the maximum number of 10 parkings					PERMIT
PA3	Accessible spaces as close as possible to the entrance of the building and no more than 50 m					PERMIT
PA4	Dimensions of accessible parking spaces: 2500 x 6000 mm for angled parking. x 6000 mm for parking along the sidewalk 2600					PERMIT
PA5	With lateral access aisle \geq 1200 mm					PERMIT
PA6	Signs mounted at 2200 mm with international symbol					ACCOMPLISH
PA7	Marked with international symbols					ACCOMPLISH
PA8	Curb cut with maximum 8% slope					ACCOMPLISH

AR	Accessible Room	YES	N/A	NON	Comments	Audit Phase
ARh	Rooms					
ARh1	rooms are accessible with accessible toilet					PERMIT
ARh2	Half of the accessible hotel rooms with roll-in showers and other half bathtubs					PERMIT
ARh3	Toilet with alarm string					OPERATION
ARh4	Clear route & 1500 x 1500 mm free space beside the bed					OPERATION
ARh5	Illumination ≥ 200 lux					ACCOMPLISH
ARh6	Controls placed at height between 700 - 1200 mm					ACCOMPLISH
ARh7	Electronic outlets at height between 400 - 1000mm					OPERATION
ARh8	The bed height ≤ 500 mm					OPERATION
ARh9	Acoustic and visual fire alarm provided and audible door bell					OPERATION
ARh10	Dressing mirror provided with front space up to 2000mm					OPERATION
ARh11	Shelves and drawers are provided between 700 -1200mm from the floor and clothes hanger placed at height 1200mm					OPERATION
ARh12	Viewing device provided in the door at height 800 - 1000mm if provided					ACCOMPLISH
Ard	Dining rooms					
ARd1	Accessible path of travel provided to half of dining area (900mm minimum)					OPERATION
ARd2	Illumination ≥ 100 lux provided in at least 10% of dining rooms					ACCOMPLISH
ARd3	Sound reduction materials used in dining rooms, floors and walls made of washable materials					OPERATION
ARd4	10% of the tables shall comply with the dimensional criteria for tables					OPERATION
ARd5	The self service tables height located between 900 - 1200mm from the floor					OPERATION
ARd6	Minimum 900mm clear passage to all food service area					OPERATION

ARd7	Spaces for children strollers and mobility devices are provided; 10 seats are movable						OPERATION
------	--	--	--	--	--	--	-----------